

Emergency Deficiencies Correction Funding Application

Initial Submission Date:

Application ID: 487

Resubmittal Date:

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

District Name: Mohave Valley Elementary District

Superintendent: Whitney Crow

Contact Person: David Berard

Contact Phone Number: 9287682507 - 9284442507

Contact Email: berardd@mvdistrict.net

School Site: Mohave Valley Junior High School

Buildings: 1002 Building B

Description of Problem

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

JH Woodshop Bldg. 1002 7 ton (18 yr old) unit - high amp reading on compressor causing the compressor to overheat and shut down.

Project Category: HVAC

Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? N

Available Funding Was money to address this issue included in your adopted budget for this fiscal year? **N**

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Current fiscal year building renewal expenditures:	\$0.00
Current balance of unrestricted capital:	\$40,000.00

Please outline any associated insurance coverage.

The district does not have sufficient funds to cover the project. The remaining \$40,000 unrestricted is earmarked for curriculum for common core requirements, and the \$1,869.13 in our BRF is earmarked for the certification of our fire panels.

Liaison: Breuer

gbreuer@azsfb.gov

602-542-6139

Superintendent Printed Name

Emergency Deficiencies Correction Funding Application

Superintendent Signature _____ Date _____